



Furbish Company
Brad Garner
3430 2nd Street - Suite 100
Baltimore, MD 21225
PHONE: 443-874-7465

Date received Sep-17-2013
Account Number 09134430
Revised Report Date Jan-29-2014
Facility EcoCline Green Roof System



ASTM E2397 Standard Practice for Determining Dead Loads & Live Loads

Lab ID#	Sample Name	Fabric Type	Specimen Thickness (mm)	Unit Weight Dry		Unit Weight Retained Water		Retained Water (Volume %)	Unit Weight Transient Water	
				(kg/m ²)	(lb/ft ²)	(kg/m ²)	(lb/ft ²)		(kg/m ²)	(lb/ft ²)
13090045-1	Water Retention Layer	Absorptive Drainage Mats	25.7	3.00	0.61	24.17	4.95	94	1.51	0.31
13090045-2	Filter Fabric	Fabrics	0.01	0.18	0.04	1.29	0.27			
13090045-6	Protection Layer	Fabrics	0.04	0.64	0.13	3.98	0.82			

A2LA Testing Certificate Number 797-01

These samples were tested as received and comments pertain only to the samples shown.
This report may not be reproduced in part, only in full.
Sample condition upon receipt was normal.
Samples were received with a transmittal letter.

Reviewed by: _____