



Turf & Soil Diagnostics



Furbish Company
 Pamela Whitaker
 3430 2nd Street, Suite 100
 Baltimore, MD 21225

Date received Jan-5-2016
 Date Reported Jan-12-2016
 Facility EcoCline

ASTM E2397 Standard Practice for Determining Dead Loads & Live Loads

Lab ID#	Sample Name	Specimen Thickness (mm)	Unit Weight Dry		Unit Weight Wet		Unit Weight Retained Water		Retained Water (Volume %)	Unit Weight Transient Water	
			lb/ft ²	kg/m ²	lb/ft ²	kg/m ²	lb/ft ²	kg/m ²		lb/ft ²	kg/m ²
16010002-3	Water Retention & Drainage Layer	30.9	1.2	5.7	7.1	34.5	5.9	28.8	93	0.36	1.73

Samples were tested as received and comments pertain only to the samples shown.
 This report may not be reproduced in part, but only in full.
 Sample condition upon receipt was normal.
 Samples were received with a transmittal letter.

Reviewed by _____